

NC/QC/YPD/2020-21/W6-WS-CB2A

Date: 24-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and drains at Westernside of R K Hegdenagara cross road and surrounding Areas in Ward No.06.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri K S Chowdareddy, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS


Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	27-03-21	24-04-21	28	22500	510	22.67	22.67
	002	"	"	"	"	500	22.22	
	003	"	"	"	"	520	23.11	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Cross Rd-1

Page No. 1/1,



Asst. Executive Engineer
Project Division

NC/QC/YPD/2020-21/W6-WS-CB3A

Date: 06-05-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and drains at Westernside of R K Hegdenagara cross road and surrounding Areas in Ward No.06.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri K S Chowdareddy, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	08-04-21	06-05-21	28	22500	495	22.00	22.15
	002	"	"	"	"	505	22.44	
	003	"	"	"	"	495	22.00	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Cross Rd-2

Page No. 1/1,

[Signature]

[Signature]

Asst. Executive Engineer
Project Division





NC/QC/YPD/2020-21/W6-WS-CB4A

Date: 17-05-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and drains at Westernside of R K Hegdenagara cross road and surrounding Areas in Ward No.06.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri K S Chowdareddy, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	19-04-21	17-05-21	28	22500	500	22.22	22.52
	002	"	"	"	"	515	22.89	
	003	"	"	"	"	505	22.44	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Shobitha House Rd

Page No. 1/1,



Asst. Executive Engineer

Project Division

NEWZEN CONSULTANT BANGALORE, #13, 10TH MAIN ROAD, 2ND CROSS JNANAJYOTHI NAGARA,

JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187

EMAIL: newzen576@gmail.com

BBMP, Bangalore - 92



NC/QC/YPD/2020-21/W6-WS-CB5A

Date: 13-07-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and drains at Westernside of R K Hegdenagara cross road and surrounding Areas in Ward No.06.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri K S Chowdareddy, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	15-06-21	13-07-21	28	22500	510	22.67	22.67
	002	"	"	"	"	500	22.22	
	003	"	"	"	"	520	23.11	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Mother Dairy Rd

Page No. 1/1,



Asst. Executive Engineer
Project Division



NC/QC/YPD/2020-21/W6-WS-CB6A

Date: 16-07-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and drains at Westernside of R K Hegdenagara cross road and surrounding Areas in Ward No.06.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri K S Chowdareddy, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	18-06-21	16-07-21	28	22500	495	22.00	22.15
	002	"	"	"	"	505	22.44	
	003	"	"	"	"	495	22.00	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Soha Provision Store

Page No. 1/1,

[Signature]
JE

[Signature]

Asst. Executive Engineer
Project Division





NC/QC/YPD/2020-21/W6-WS-CB6A

Date: 16-07-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and drains at Westernside of R K Hegdenagara cross road and surrounding Areas in Ward No.06.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri K S Chowdareddy, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	18-06-21	16-07-21	28	22500	495	22.00	22.15
	002	"	"	"	"	505	22.44	
	003	"	"	"	"	495	22.00	

The result of the materials tested meets the standards and hence can be used for the work.

Sample Collected Site : Soha Provision Store

Page No. 1/1,

Asst. Executive Engineer
Project Division



NC/QC/YPD/2020-21/W6-WS-CB7A

Date: 21-07-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and drains at Westernside of R K Hegdenagara cross road and surrounding Areas in Ward No.06.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri K S Chowdareddy, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	23-06-21	21-07-21	28	22500	525	23.33	22.96
	002	"	"	"	"	515	22.89	
	003	"	"	"	"	510	22.67	

The result of the materials tested meets the standards and hence can be used for the work.

Sample Collected Site : Government School Opp Rd 4th Cross Rd

Page No. 1/1,

[Signature]

**Asst. Executive Engineer
Project Division
Yelahanka Zone**



NC/QC/YPD/2020-21/W6-WS-K1

Date: 07-07-2021

TEST REPORT

Sub: Testing of Pre-cast Material-Kerb Stones.

{Project*: Improvements to roads and drains at Westernside of R K Hegdenagara cross road and surrounding Areas in Ward No.06.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri K S Chowdareddy, Bangalore.

1. PHYSICAL TESTS ON KERB STONES :

Sl No.	Identification	Flexural strength, fcr in N/sqmm	Characteristic Compressive Strength, fck in N/sqmm	Avg. Characteristic Compressive Strength fck in N/sqmm	Remarks
1	001	3.35	22.95	22.83	As per Cl. 6.2.2 of IS 456- 2000, $f_{cr}=0.7\sqrt{f_{ck}}$
2	002	3.29	22.10		
3	003	3.39	23.45		

2. WATER ABSORPTION TEST

Sl No	Identification	Water absorption %	Average value %
1	001	4.56	4.52
2	002	4.38	
3	003	4.64	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Cross Rd-2

Page No. 1/1

Asst. Executive Engineer
Project Division



NC/QC/NPD/2020-21/W6-WS-K2

Date: 12-07-2021

TEST REPORT

Sub: Testing of Pre-cast Material-Kerb Stones.
{Project*: Improvements to roads and drains at Westernside of R K Hegdenagara cross road and surrounding Areas in Ward No.06.}

Ref.: Material testing/PMC/20-21,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri K S Chowdareddy, Bangalore.

1. PHYSICAL TESTS ON KERB STONES:

Sl No.	Identification	Flexural strength, fcr in N/sqmm	Characteristic Compressive Strength, fck in N/sqmm	Avg. Characteristic Compressive Strength fck in N/sqmm	Remarks
1	001	3.31	22.40	22.98	As per Cl. 6.2.2 of IS 456-2000, fcr=0.7√ fck
2	002	3.39	23.45		
3	003	3.36	23.10		

2. WATER ABSORPTION TEST

Sl No	Identification	Water absorption %	Average value %
1	001	4.58	4.66
2	002	4.74	
3	003	4.66	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : 6th Cross Rd

Page No. 1/1

**Asst. Executive Engineer**

Project Division

NEWZEN CONSULTANT BANGALORE, #13, 10TH MAIN ROAD 2ND CROSS, JNANABHARATHI, BANGALORE-560056. CELL NO: 91879262031, 08923240187
EMAIL: newzen576@gmail.com



NC/QC/YPD/2020-21/W6-WS-K3

Date: 15-07-2021

TEST REPORT

Sub: Testing of Pre-cast Material-Kerb Stones.

{Project*: Improvements to roads and drains at Westernside of R K Hegdenagara cross road and surrounding Areas in Ward No.06.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri K S Chowdareddy, Bangalore.

1. PHYSICAL TESTS ON KERB STONES :

Sl No.	Identification	Flexural strength, fcr in N/sqmm	Characteristic Compressive Strength, fck in N/sqmm	Avg. Characteristic. Compressive Strength fck in N/sqmm	Remarks
1	001	3.34	22.90	23.26	As per Cl. 6.2.2 of IS 456- 2000, $fcr=0.7\sqrt{fck}$
2	002	3.37	23.30		
3	003	3.40	23.60		

2. WATER ABSORPTION TEST

Sl No	Identification	Water absorption %	Average value %
1	001	4.49	4.49
2	002	4.38	
3	003	4.61	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Mother Dairy Rd

Page No. 1/1



Asst. Executive Engineer

Project Division
Yelahanka Zone

NEWZEN CONSULTANT BANGALORE, #13, 10TH MAIN ROAD, 2ND CROSS, JNANAJYOTHI NAGARA,
JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL: newzen576@gmail.com

BBMP, Bangalore - 92

NC/QC/YPD/2020-21/W6-WS-K4

Date: 20-07-2021

TEST REPORT

Sub: Testing of Pre-cast Material-Kerb Stones.
{Project*: Improvements to roads and drains at Westernside of R K Hegdenagara cross road and surrounding Areas in Ward No.06.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri K S Chowdareddy, Bangalore.

1. PHYSICAL TESTS ON KERB STONES :

Sl No.	Identification	Flexural strength, fer in N/sqmm	Characteristic Compressive Strength, fck in N/sqmm	Avg. Characteristic Compressive Strength fck in N/sqmm	Remarks
1	001	3.34	22.80	23.13	As per Cl. 6.2.2 of IS 456- 2000, $f_{cr}=0.7\sqrt{f_{ck}}$
2	002	3.38	23.40		
3	003	3.37	23.20		

2. WATER ABSORPTION TEST

Sl No	Identification	Water absorption %	Average value %
1	001	4.59	4.64
2	002	4.71	
3	003	4.64	

The result of the materials tested meets the standards and hence can be used for the work.

Sample Collected Site : Cross Rd-7

Page No. 1/1

[Signature]

[Signature]

Asst. Executive Engineer

Project Division



NEWZEN CONSULTANT BANGALORE, #13, 10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA,

JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187

EMAIL: newzen576@gmail.com

BBMP, Bangalore - 92

NC/QC/YPD/2020-21/W6-WS-K5

Date: 27-07-2021

TEST REPORT

Sub: Testing of Pre-cast Material-Kerb Stones.

{Project*: Improvements to roads and drains at Westernside of R K Hegdenagara cross road and surrounding Areas in Ward No.06.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri K S Chowdareddy, Bangalore.

1. PHYSICAL TESTS ON KERB STONES :

Sl No.	Identification	Flexural strength, fcr in N/sqmm	Characteristic Compressive Strength, fck in N/sqmm	Avg. Characteristic. Compressive Strength fck in N/sqmm	Remarks
1	001	3.33	22.75	23.11	As per Cl. 6.2.2 of IS 456-2000, fcr=0.7√ fck
2	002	3.36	23.10		
3	003	3.39	23.50		

2. WATER ABSORPTION TEST

Sl No	Identification	Water absorption %	Average value %
1	001	4.53	4.52
2	002	4.39	
3	003	4.65	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Cross Rd-3

Page No. 1/1

[Signature]



[Signature]

Asst. Executive Engineer

Project Division



NC/QC/YPD/2020-21/W6-WS-K6

Date: 29-07-2021

TEST REPORT

Sub: Testing of Pre-cast Material-Kerb Stones.

{Project*: Improvements to roads and drains at Westernside of R K Hegdenagara cross road and surrounding Areas in Ward No.06.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri K S Chowdareddy, Bangalore.

1. PHYSICAL TESTS ON KERB STONES :

Sl No.	Identification	Flexural strength, fcr in N/sqmm	Characteristic Compressive Strength, fck in N/sqmm	Avg. Characteristic. Compressive Strength fck in N/sqmm	Remarks
1	001	3.35	22.95	23.30	As per Cl. 6.2.2 of IS 456-2000, fcr=0.7√ fck
2	002	3.38	23.35		
3	003	3.40	23.60		

2. WATER ABSORPTION TEST

Sl No	Identification	Water absorption %	Average value %
1	001	4.53	4.55
2	002	4.46	
3	003	4.68	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Cross Rd-4

Page No. 1/1



Asst. Executive Engineer



NC/QC/YPD/2020-21/W6-WS-K7

Date: 31-07-2021

TEST REPORT

Sub: Testing of Pre-cast Material-Kerb Stones.
{Project*: Improvements to roads and drains at Westernside of R K Hegdenagara cross road and surrounding Areas in Ward No.06.}
Ref.: Material testing/PMC/20-21,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: Sri K S Chowdareddy, Bangalore.

1. PHYSICAL TESTS ON KERB STONES :

Sl No.	Identification	Flexural strength, fcr in N/sqmm	Characteristic Compressive Strength, fck in N/sqmm	Avg. Characteristic. Compressive Strength fck in N/sqmm	Remarks
1	001	3.33	22.75	23.13	As per Cl. 6.2.2 of IS 456- 2000, fcr=0.7√ fck
2	002	3.38	23.45		
3	003	3.37	23.20		

2. WATER ABSORPTION TEST

Sl No	Identification	Water absorption %	Average value %
1	001	4.64	4.49
2	002	4.49	
3	003	4.36	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Shobitha House Rd

Page No. 1/1

[Handwritten signatures]



Asst. Executive Engineer



Date: 04-08-2021

NC/QC/YPD/2020-21/W6-WS-K8

TEST REPORT

Sub: Testing of Pre-cast Material-Kerb Stones.

{Project*: Improvements to roads and drains at Westernside of R K Hegdenagara cross road and surrounding Areas in Ward No.06.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri K S Chowdareddy, Bangalore.

1. PHYSICAL TESTS ON KERB STONES :

Sl No.	Identification	Flexural strength, f_{cr} in N/sqmm	Characteristic Compressive Strength, f_{ck} in N/sqmm	Avg. Characteristic Compressive Strength f_{ck} in N/sqmm	Remarks
1	001	3.32	22.50	23.00	As per Cl. 6.2.2 of IS 456-2000, $f_{cr}=0.7\sqrt{f_{ck}}$
2	002	3.38	23.40		
3	003	3.36	23.10		

2. WATER ABSORPTION TEST

Sl No	Identification	Water absorption %	Average value %
1	001	4.53	4.63
2	002	4.71	
3	003	4.67	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Cross Rd-5

Page No. 1/1

[Signature]
JE

[Signature]

Asst. Executive Engineer
Project Division





NC/QC/YPD/2020-21/W6-WS-K9

Date: 06-08-2021

TEST REPORT

Sub: Testing of Pre-cast Material-Kerb Stones.
{Project*: Improvements to roads and drains at Westernside of R K Hegdenagara cross road and surrounding Areas in Ward No.06.}

Ref.: Material testing/PMC/20-21,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri K S Chowdareddy, Bangalore.

1. PHYSICAL TESTS ON KERB STONES :

Sl No.	Identification	Flexural strength, fcr in N/sqmm	Characteristic Compressive Strength, fck in N/sqmm	Avg. Characteristic Compressive Strength fck in N/sqmm	Remarks
1	001	3.36	23.10	23.28	As per Cl. 6.2.2 of IS 456- 2000, $f_{cr}=0.7\sqrt{f_{ck}}$
2	002	3.39	23.50		
3	003	3.37	23.25		

2. WATER ABSORPTION TEST

Sl No	Identification	Water absorption %	Average value %
1	001	4.73	4.65
2	002	4.65	
3	003	4.58	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Ex-Man Service Rd

Page No. 1/1

Asst. Executive Engineer
Project Division
Yelahanka Zone





NC/QC/YPD/2020-21/W6-WS-CB8

Date: 03-08-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).

{Project*: Improvements to roads and drains at Westernside of R K Hegdenagara cross road and surrounding Areas in Ward No.06.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri K S Chowdareddy, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M₁₅

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	27-07-21	03-08-21	07	22500	320	14.22	13.93
	002	"	"	"	"	305	13.56	
	003	"	"	"	"	315	14.00	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Medio Pharama Shop Rd

Page No. 1/1,

[Signature]



Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore

Date: 24-08-2021

NC/QC/YPD/2020-21/W6-WS-CB8A

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and drains at Westernside of R K Hegdenagara cross road and surrounding Areas in Ward No.06.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri K S Chowdareddy, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M₁₅

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	27-07-21	24-08-21	28	22500	425	18.89	18.89
	002	"	"	"	"	435	19.33	
	003	"	"	"	"	415	18.44	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Medio Pharama Shop Rd

Page No. 1/1,

[Signature]

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

